



BOROUGH OF PARAMUS
1 JOCKISH SQUARE
PARAMUS, NEW JERSEY
 07652 201 265-2100 ext. 2290
 Fax 201 265-5631

Fire Prevention Bureau
 Paramus Fire Department

NEW JERSEY UNIFORM FIRE CODE
 NEW JERSEY ADMINISTRATIVE CODE TITLE: 5
 CHAPTER 70

TYPE 1 PERMIT

NJAC 5:70-2.9(c)1.

FEE: \$42.00

NJAC 5:70-2.7(a)3iv. Kiosk:

Individual portable kiosks or displays when erected in a covered mall for a period of 90 days or less and when not covered by a TYPE 2 Permit:

Name: _____

Address: _____

Telephone: _____

Name of Mall: _____ Date to be held _____ to _____

Items to be sold: _____

Any flame producing device to be used: YES NO

After fee is paid and inspection is made by this office, a permit will be issued.

Requirements:

1. A plan of mall showing location of proposed display booths or kiosks within mall must be submitted. There shall be a minimum of 10 feet clear exit width to a height of 8 feet between any projection of a tenant space bordering the mall and the nearest kiosk, display booth, concession equipment, bench, or like.
2. Temporary kiosks shall conform to International Building Code 2000 NJ edition section 402 "Covered Malls".
 - 402.10.1. Construction: Combustible kiosks or other structures shall not be located within the mall unless constructed of fire-retardant-treated wood
 - 402.10.2. Fire Suppression: Kiosks or other structures located within the mall shall be provided with approved fire suppression and detection devices.
 - 402.10.3. Horizontal Separation: The minimum horizontal separation between kiosks and other structures within the mall shall be 20 feet.
 - 402.10.4. Maximum Area: each kiosks or other similar structures shall have a maximum of 300 square feet.
3. Fire extinguishers are required. One (1) ABC Dry Chemical fire extinguisher, minimum of 5 pounds per kiosk.
4. Temporary electrical wiring must conform to National Electric Code N.F.P.A. #70 section 305. The wiring must be protected on floor from accidental damage, as per section 305-4H. Metal or rubber floor mold or any other approved device to properly protect wire will be accepted.

I hereby acknowledge that I have read the above, and all information given is correct, and I agree to abide by the above requirements.

Signature: _____ Date: _____